



CERTIFICATE FI 29975

Our Ref. 289312

Product Installation conduit, pliable

Type ICTAQ (EasyFlow+)

Trade mark PM

Certificate Holder P.M. Plastic Materials S.R.L.
Via XXV Aprile, 15 24030 Almenno, SAN BARTOLOMEO (BG), ITALY

Manufacturer P.M. Plastic Materials S.R.L.
Via XXV Aprile, 15 24030 Almenno, SAN BARTOLOMEO (BG), ITALY

Technical information Corrugated conduits of grey and of black insulated material
Non-flame propagating conduits

Other information Classification Code 3342 or 3422. See appendix

The product is certified according to the following standard(s) EN 61386-1:2008
EN 61386-22:2004 + A11:2010

Validity This certificate is valid until 12 June 2022 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that product changes (if any) will be approved at SGS Fimko before the product is brought onto market.

Directive information The certified product(s) fulfils requirements of above mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.

Date of issue 12 June 2017

SGS Fimko Ltd

Signature

Matti Huttunen
Certification Engineer

This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Appendix to Certificate: 29975

Manufacturing sites

P.M. Plastic Materials S.R.L.
Via XXV Aprile, 15 24030 Almenno, SAN BARTOLOMEO (BG),
ITALY

Additional information

The product has certificate 1710603 issued by Intertek Semko AB in accordance with the Nordic Certification Service system.



No halogen according to EN 60754-1:2014 and EN 60754-2:2014.
The conduits comply with requirement according to Low Smoke Test "LSZH" according to IEC 61034-2:2005

Different types of conduits:

Conduit with diameter 16mm: Grey with orange bands
Conduit with diameter 20mm: Grey with blue bands
Conduit with diameter 25mm: Grey with yellow bands

Conduit with diameter 16mm: Black with orange bands
Conduit with diameter 20mm: Black with blue bands
Conduit with diameter 25mm: Black with yellow bands

Our ref. no.

289312-1

MOR