

| | |
|---|--|
| Product | Conduits for electrical installations |
| Applicant | PM Plastic Materials S.R.L. Via XXV Aprile, 15 24030 Almenno San Bartolomeo (BG) Italy |
| Manufacturer | PM Plastic Materials S.R.L. Via XXV Aprile, 15 24030 Almenno San Bartolomeo (BG) Italy |
| Factory | PM Plastic Materials s.r.l Via XXV Aprile, 15 24030 Almenno San Bartolomeo (BG) Italy |
| Ratings | 16mm |
| Trade mark | PM |
| Model / Type Ref. | ICTAQ (EasyFlow+) |
| Principal characteristics | Corrugated conduit, grey insulated material with orange band. Classification code 3342 or 3422. None- flame propagating conduits. |
| A sample of the product was tested and found to be in conformity with | INST EN 61386-1:2008 EN 61386-22:2004;A11 |
| Validity | This certificate documents conformity with the standards shown, and also applies as license for use of Nemkos name and certification mark. The certificate and license is valid as long as the applicable conditions are complied with, and provided that any changes to the product are notified to Nemko for acceptance prior to implementation. New standards or amendments to the standards may imply that the product design must be updated and/or that re-testing and re-certification is necessary. |
| Additional information | See page 2 |
| Additional model(s) | (5) See page 2 |

Date of issue 12-06-2017



Nastaran Vadoodi
Certification Department

Nemko AS

Gaustadalléen 30, P.O. Box 73 Blindern, 0314 Oslo, Norway
TEL +47 22 96 03 30 FAX +47 22 96 05 50 EMAIL info@nemko.com
ENTERPRISE NUMBER NO974404532

Additional model(s)

| | |
|---------------------------------------|---|
| Product | Conduits for electrical installations |
| Pos. No | 1 |
| Model / Type Ref. | ICTAQ (EasyFlow+) |
| Trade mark (if different from page 1) | |
| Rating | 20mm |
| Principal characteristics | Corrugated conduit, grey insulated material with blue band. Classification code 3342 or 3422 . None- flame propagating conduits. |
| Product | Conduits for electrical installations |
| Pos. No | 2 |
| Model / Type Ref. | ICTAQ (EasyFlow+) |
| Trade mark (if different from page 1) | |
| Rating | 25mm |
| Principal characteristics | Corrugated conduit, grey insulated material with yellow band. Classification code 3342 or 3422. None- flame propagating conduits. |
| Product | Conduits for electrical installations |
| Pos. No | 3 |
| Model / Type Ref. | ICTAQ (EasyFlow+) |
| Trade mark (if different from page 1) | |
| Rating | 16mm |
| Principal characteristics | Corrugated conduit, black insulated material with orange band. Classification code 3342 or 3422. None- flame propagating conduits. |
| Product | Conduits for electrical installations |
| Pos. No | 4 |
| Model / Type Ref. | ICTAQ (EasyFlow+) |
| Trade mark (if different from page 1) | |
| Rating | 20mm |
| Principal characteristics | Corrugated conduit, black insulated material with blue band. Classification code 3342 or 3422. None- flame propagating conduits. |
| Product | Conduits for electrical installations |
| Pos. No | 5 |
| Model / Type Ref. | ICTAQ (EasyFlow+) |
| Trade mark (if different from page 1) | |
| Rating | 25mm |
| Principal characteristics | Corrugated conduit, black insulated material with yellow band. Classification code 3342 or 3422. None- flame propagating conduits. |
| Additional information | No halogen according to EN 60754-1:2014 and EN 60754-2:2014. The conduits comply with requirement according to Low Smoke Test "LSZH" according to IEC 61034- 2:2005. |

Date of issue 12-06-2017



Nastaran Vadoodi
Certification Department