



LICENCE

No. 15652 - Issue No 2

Issued to:
Applicant:
P.M. Plastic Materials S.r.l
Via Garibaldi 44
24031 Almenno S. Salvatore (BG)
Italy



Licensee:
P.M. Plastic Materials S.r.l
Via Garibaldi 44
24031 Almenno S. Salvatore (BG)
Italy



Product : conduit systems for cable management
Trade name(s) : PM
Type(s)/model(s) : ICTA

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.


SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 1223

SGS CEBEC hereby grants the right to use the CEBEC certification mark

The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on: 09/06/2011


ir. C. Lana,
Certification Manager

© Only integral publication of this certificate, including the annex, is allowed
This certificate is only valid combined with the publication on the following web address: www.sgs.com/ee



005-PROD



SGS Belgium NV-Division SGS CEBEC
Business Riverside Park
Bld Internationalelaan 55 Build. D
B-1070 Brussels
Tel.+32(0)2 556 00 20 Fax.+32(0)2 556 00 36

This certificate is issued by the company under its General Conditions for Certification Services accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitations of liability defined therein and in the Test Report herein mentioned which findings are reflected in this Certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	:	conduit systems for cable management
Trade name(s)	:	PM
Type(s)/Model(s)	:	ICTA
nominal size(s) (outside diameters)	:	16, 20, 25, 32, 40, 50 mm
classification	:	3422
type of conduit	:	non-metallic/corrugated
method of connection	:	non-threadable
resistance to bending	:	pliable/self-recovering
flame propagation	:	non-flame propagation
colour(s)	:	black, grey, blue, ivory, green

Additional information

Classification coding

First digit : 3	Medium compression strength	750 N
Second digit : 4	Heavy impact strenght	2 kg/300 mm
Third digit : 2	Minimum permanent application and installation temperature	-5°C
Fourth digit : 2	Maximum permanent application and installation temperature	+90°C
Fifth digit : 3	Resistance to bending Pliable/self-recovering	

TESTS

Test requirements

NBN EN 61386-1 based on EN 61386-1:2004
NBN EN 61386-22 based on EN 61386-22:2004

Remarks

This certificate is based on certificate ref. NTR-26935/IMQ-A1 and test report(s) ref. 02AH00142


Conclusion

The examination proved that all test requirements were met.

Checked by, project leader : Zanutto Luigi - 09/06/2011

Department Manager, :
Product Certification :

Certification Manager :





FACTORY LOCATION(S)

P.M. Plastic Materials S.r.l
Via XXV Aprile 15
24030 Almenno S. Bartolomeo (BG)
Italy